# Shielding analysis for the In-Flight Fragment target facility of the RAON complex in Korea

Cheol-Woo Lee (KAERI)

23, Sept., 2019

@ Institute for Basic Science

#### **Contents**

- Introduction
- Evaluation of source terms and bulk shield thickness
- Shielding analysis for the prompt radiation field
  - Estimation of dose rate and dose mapping
- Activation analysis
  - Air
  - Coolant
  - Target and beam transport equipment
  - Structural material (concrete)

## **Analysis code system**

| Analysis                                    | Code   | Reaction model                  | Library                             |
|---|--|---------------------------------|-------------------------------------|
| Source term                                 | PHITS 2.64   | JQMD + JAM +<br>INCL            | JENDL-HE 2007, ENDF/B VI            |
| Bulk shield thickness                       | MCNPX 2.7  | Bertini                         | JENDL-HE 2007, ENDF/B VI            |
| Shielding design for prompt radiation field | MCNPX 2.7 +<br>Advantg 3.1                                 | Bertini                         | JENDL-HE 2007, ENDF/B VI            |
| Activation analysis                         | PHITS 2.64 +<br>MCNPX 2.7 +<br>DCHAIN/SP(2011) or FISPACT* | JQMD + JAM +<br>INCL or Bertini | JENDL-HE 2007, ENDF/B VI<br>EAF2010 |

<sup>\*</sup>FISPACT: modified version based on the FISPACT2010 for spallation reaction analysis (Chang Ho Shin, Hanyang univ.)

## Evaluation of source term for shielding design and analysis


- 1) Evaluation of the charged particle distribution
- Stopping rage of the energetic primary beam was calculated by SRIM code.
  - The stopping range of the Oxygen beam with 590 MeV/n is 6.84 cm in the iron.
  - The heavier beam particle has the shorter stopping range.


| Primary beam | Energy [MeV/n] | Stopping range [cm] |
|--------------|----------------|---------------------|
| O-16         | 590            | 6.84                |
| Ca-48        | 550            | 2.97                |
| Kr-86        | 550            | 1.64                |
| Sn-112       | 550            | 1.12                |
| U-238        | 400            | 0.47                |

## Evaluation of source term for shielding design and analysis

#### 2) Comparison of neutron and gamma

- Comparison of the neutron and gamma spectra produced from the IFF target: O-16 beam, 590 MeV/n
- Comparison of contribution to dose rate behind the concrete shield:
- The contribution of gammas to dose rate is less than 0.1%. Therefore the secondary neutrons produced by the primary beam is considered as the source term for the radiation shielding analysis







## Evaluation of source term for shielding design and analysis

Neutron source term in each area of the IFF target facility


| Area                            | Neutron production | Material               | Beam loss (intensity) |
|---------------------------------|--------------------|------------------------|-----------------------|
| High energy beam transport room | @ beam line        | SS beam line           | 1 W/m beam loss       |
|                                 | @ target           | Graphite target        | 20% beam loss         |
| Pre-separator room              | @ beam dump        | Water dump             | 80% beam loss         |
|                                 | @ pre-separator    | Pre-separator material | Full beam loss (100%) |
| Main separator room             | @ main separator   | Magnet material        | Isotope loss data     |




- Neutron spectra produced at each angle
  - It is expected that O-16 beam produces most conservative source term.




- Neutron spectra at each beam loss point
  - At Target, dump and pre-separator



Beam loss positions in the main separator room




- In main separator room, many isotopes produced from target are distributed. About 400 nuclides will be loss.
- It is impossible to applying all isotopes loss.
- Most conservative neutron spectra was produced with the Tm-173 isotope, and it is applied as the source term.
- Neutron spectra produced by Tm-173



#### **Evaluation of the bulk shield thickness**


With the source terms, the bulk shied thicknesses satisfying the requirement of exposure limit t be used initial facility design.

- Source term:
  - O-16 beam, 590 MeV/n + target & dump
- Requirement of exposure limit:
  - 5 uSv/hr for radiation workers
  - 0.25 uSv/hr for the public




## Attenuation of dose rate by the shield

Using the concrete shield only




## Attenuation of dose rate by the shield

- Using the combination of concrete and iron as the shield
  - To reduce the shield thickness, iron shield was inserted into the concrete shield.
  - The high energetic neutrons loss more energy by the inelastic reactions with the high-Z materials such as iron than the light elements.



## Attenuation of dose rate by the shield

Using the combination of concrete and iron as the shield



#### Determination of the bulk shield thickness

- The bulk shield thickness was reflected in the facility design.
  - The BW is the high energy beam transport room and a prohibited area.
  - In the simplified calculation model, the height of the room is considered as 2m, but the real design value is more higher and removal shield was added.

| Position | Bulk shield thickness [cm] |          | Dose rat<br>shield [ | e behind<br>uSv/hr] | Designated wall thickness [cm] |      |          |       |
|----------|----------------------------|----------|----------------------|---------------------|--------------------------------|------|----------|-------|
|          | Iron                       | concrete | Total                | Calculati<br>on     | Require<br>ment                | iron | concrete | total |
| FW       | 150                        | 680      | 830                  | 4.10                | 5.00                           | 300  | 800      | 1100  |
| BW       | 0                          | 630      | 630                  | 4.11                | -                              | 0    | 180      | 180   |
| SW-R     | 150                        | 650      | 800                  | 4.82                | 5.00                           | 173  | 689      | 862   |
| SW-L     | 150                        | 430      | 590                  | 4.88                | 5.00                           | 173  | 589      | 762   |
| Roof     | 150                        | 510      | 660                  | 4.53                | -                              | 150  | 100      | 250   |


#### Radiation area of RAON

 According to the domestic regulatory based on the ICRP recommendation, the radiation area was consisted and dose rate limit was applied.

|                         |                           | Regulatory  |  | Designated dasa                              |                       |
|-------------------------|---------------------------|-------------|--|--|-----------------------|
| Area                    |                           | Regulations | Conversion to<br>dose rate (2000<br>hr/yr) | Designated dose<br>rate<br>(Safety factor 2) | Entrance<br>condition |
|                         | Worker's area             |             | < 10 uSv/hr                                | < 5 uSv/hr                                   | Not limited           |
| Radiation area          | Limited area              | < 20 mSv/yr | < 10 usv/III                               | < 5 usv/III                                  | Limited               |
|                         | High level radiation area |             | > 10 uSv/hr                                | -  | Prohibition           |
| Outside of the facility | Public area               | < 1 mSv/yr  | < 0.5 uSv/hr                               | < 0.25 uSv/hr                                | Not limited           |

#### **Evaluation of dose rate distribution**

- For the facility design, dose rate distribution at each interesting positions was evaluated.
- Total 16 calculation points were selected considering penetration holes, entrance area, door etc.




## Dose rates in the IFF target facility

All calculated dose rate satisfied with the designated limit.

| #  | Floor | 위치 개요   | Radiation area | Limit<br>[uSv/hr] | Calculated dose<br>rate<br>[uSv/hr] |
|----|-------|---|----------------|-------------------|-------------------------------------|
| 1  | B1    | Side of the IFF target                            |                |                   | 3.8                                 |
| 2  | B1    | Side of the beam dump                             |                |                   | 4.5                                 |
| 3  | B1    | Front of the beam dump                            |                |                   | 4.2                                 |
| 4  | B1    | Door of cooling system room                       |                |                   | 1.2E-02                             |
| 5  | B2    | Entrance are of the drained water processing room |                | < 5               | 5.2E-04                             |
| 6  | B2    | Entrance of the rad-waste storage room            | Limited area   |                   | 2.3E-05                             |
| 7  | 1F    | Inside of the Window station room                 |                |                   | 8.7E-03                             |
| 8  | 1F    | Inside of the remote control room                 |                |                   | 5.4E-05                             |
| 9  | 1F    | Side of the remote control room                   |                |                   | 2.4E-04                             |
| 10 | 1F    | Entrance of the remote control room               |                |                   | 3.4E-03                             |
| 11 | 2F    | Entrance of the 2F                                |                |                   | 1.7E-10                             |
| 12 | 2F    | HEBT room inside                                  |                |                   | 2.4E-12                             |
| 13 | 2F    | Electricity room inside                           | Worker's are   |                   | 2.4E-12                             |
| 14 | 2F    | UPS room inside                                   |                |                   | 4.1E-13                             |
| 15 | 2F    | Aisle   | Limited area   |                   | 6.6E-17                             |
| 16 | 3F    | Ventilation room entrance                         | Limited area   |                   | 3.2E-08                             |

#### Dose map

- With the final facility design, dose map was produced.
- From the dose map, it's expected the dose rates distributed inside the facility satisfy with the limit in the all area.




#### **Evaluation of air activation**

- Induced activities inside the facility were evaluated with the neutron source term and geometric model.
- Source term:
  - 1)High energy beam transport room: 1 W/m beam loss
  - 2)Pre-separator room: 20% beam loss at the target and 80% beam loss at the dump
  - 3) Main separator room: beam loss at the every loss position

#### **Evaluation of air activation**

Calculation area for air activation




## Long-lived radio-active nuclide release

- The release of the long-live radio-active nuclides, H-3 and C-14, were estimated less than 0.3 mg
- In this estimation, the operation time of 5000 hour per year is assumed, conservatively.


| Aroa                            | Activity | [Bq/cc]  | Activit  | Activity [Bq] |  |
|---------------------------------|----------|----------|----------|---------------|--|
| Area                            | H-3      | C-14     | H-3      | C-14          |  |
| High energy beam transport room | 1.92E-04 | 4.57E-05 | 1.44E+06 | 3.43E+05      |  |
| Pre-separator room              | 1.63E-04 | 1.31E-04 | 2.00E+06 | 1.61E+06      |  |
| Main separator room             | 7.59E-08 | 1.72E-07 | 4.44E+03 | 1.01E+04      |  |
| Activity after 2                | 3.45E+06 | 1.96E+06 |          |               |  |
| Total release d                 | 8.62E+07 | 4.91E+07 |          |               |  |
| Total release d                 | 2.41E-04 | 2.97E-01 |          |               |  |

## **Evaluation of coolant activation**




Target

Collimator










#### **Evaluation of coolant activation**

• Quadrupole:



Hexapole:





#### **Evaluation of coolant activation**

- Various radio-active nuclides are produced in the water.
- Most of them are produced primary beam spallation.
- The cooling system of the closed loop should be installed.

| Nuclide |      | Saturation concentration Half-lif |          |
|---------|------|-----------------------------------|----------|
| Nuc     | ilue | [Bq/cc]                           | [sec]    |
| Н       | 3    | 1.23E+10                          | 3.89E+08 |
| Be      | 7    | 7.64E+09                          | 4.60E+06 |
| Be      | 10   | 1.92E+03                          | 4.77E+13 |
| Be      | 11   | 6.41E+08                          | 1.38E+01 |
| C       | 10   | 2.97E+09                          | 1.93E+01 |
| С       | 11   | 1.36E+10                          | 1.22E+03 |
| С       | 14   | 4.48E+05                          | 1.81E+11 |
| С       | 15   | 4.94E+08                          | 2.45E+00 |
| N       | 13   | 7.88E+09                          | 5.98E+02 |
| N       | 16   | 2.90E+09                          | 7.12E+00 |
| N       | 17   | 4.26E+07                          | 4.17E+00 |
| N       | 18   | 1.21E+07                          | 6.30E-01 |
| 0       | 13   | 5.98E+07                          | 8.58E-03 |
| 0       | 14   | 1.52E+10                          | 7.06E+01 |
| 0       | 15   | 4.38E+10                          | 1.22E+02 |
| 0       | 19   | 3.99E+07                          | 2.69E+01 |
| F       | 17   | 5.98E+07                          | 6.45E+01 |
| F       | 18   | 1.59E+08                          | 6.59E+03 |
| F       | 20   | 1.99E+07                          | 1.10E+01 |
| F       | 21   | 3.99E+07                          | 4.32E+00 |
| F       | 22   | 3.99E+07                          | 4.24E+00 |
| Ne      | 23   | 1.99E+07                          | 3.72E+01 |
| Ne      | 24   | 1.99E+07                          | 2.03E+02 |
| Na      | 24   | 5.98E+07                          | 5.39E+04 |
| Na      | 25   | 3.99E+07                          | 5.96E+01 |
| Mg      | 27   | 1.29E+03                          | 5.68E+02 |
| Mg      | 28   | 1.99E+07                          | 7.53E+04 |
| Al      | 28   | 9.97E+07                          | 1.35E+02 |
| Al      | 29   | 3.99E+07                          | 3.94E+02 |
| Al      | 30   | 3.99E+07                          | 3.60E+00 |


| 31 | 31 | 7.97E+07 | 9.20E+03 |
|----|----|----------|----------|
| Si | 32 | 4.58E+04 | 5.43E+09 |
| Si | 33 | 1.99E+07 | 6.11E+00 |
| Si | 34 | 1.99E+07 | 2.77E+00 |
| Р  | 30 | 1.99E+07 | 1.50E+02 |
| Р  | 32 | 2.19E+08 | 1.23E+06 |
| Р  | 33 | 1.39E+08 | 2.20E+06 |
| Р  | 34 | 3.99E+07 | 1.24E+01 |
| Р  | 35 | 5.98E+07 | 4.73E+01 |
| Р  | 37 | 1.99E+07 | 2.31E+00 |
| S  | 35 | 1.77E+08 | 7.56E+06 |
| S  | 37 | 3.99E+07 | 2.99E+02 |
| Cl | 36 | 3.14E+02 | 9.50E+12 |
| Cl | 38 | 9.97E+07 | 2.23E+03 |
| Cl | 39 | 1.99E+07 | 3.34E+03 |
| Cl | 42 | 1.99E+07 | 6.80E+00 |
| Ar | 37 | 1.32E+08 | 3.03E+06 |
| Ar | 39 | 2.91E+05 | 8.49E+09 |
| Ar | 41 | 7.97E+07 | 6.58E+03 |
| Ar | 42 | 4.76E+05 | 1.04E+09 |
| K  | 42 | 1.40E+08 | 4.45E+04 |
| K  | 43 | 5.98E+07 | 8.03E+04 |
| K  | 44 | 1.99E+07 | 1.33E+03 |
| K  | 45 | 1.20E+08 | 1.04E+03 |
| K  | 46 | 3.99E+07 | 1.05E+02 |
| K  | 47 | 1.99E+07 | 1.75E+01 |
| Ca | 45 | 1.17E+08 | 1.41E+07 |
| Ca | 47 | 3.99E+07 | 3.92E+05 |
| Ca | 49 | 3.99E+07 | 5.23E+02 |
| Ca | 50 | 1.99E+07 | 1.39E+01 |
| Ca | 30 | 1.99E+07 | 1.33E+0  |

7.97E+07


9.26E+03

| Sc | 43  | 1.99E+07 | 1.40E+04 |
|----|-----|----------|----------|
| Sc | 44  | 5.98E+07 | 1.41E+04 |
| Sc | 44m | 7.03E+02 | 2.11E+05 |
| Sc | 46  | 1.80E+08 | 7.24E+06 |
| Sc | 46m | 5.73E+04 | 1.87E+01 |
| Sc | 47  | 2.39E+08 | 2.94E+05 |
| Sc | 48  | 1.59E+08 | 1.57E+05 |
| Sc | 49  | 1.40E+08 | 3.43E+03 |
| Sc | 50  | 3.95E+07 | 1.03E+02 |
| Sc | 51  | 7.97E+07 | 1.24E+01 |
| Sc | 52  | 1.99E+07 | 8.20E+00 |
| Ti | 45  | 5.98E+07 | 1.11E+04 |
| Ti | 51  | 1.79E+08 | 3.46E+02 |
| Τi | 52  | 5.98E+07 | 1.02E+02 |
| Τi | 53  | 1.99E+07 | 3.27E+01 |
| V  | 48  | 2.19E+08 | 1.38E+06 |
| V  | 49  | 9.18E+07 | 2.85E+07 |
| V  | 52  | 1.99E+08 | 2.25E+02 |
| V  | 53  | 1.40E+08 | 9.66E+01 |
| V  | 54  | 1.99E+07 | 4.98E+01 |
| V  | 55  | 7.97E+07 | 6.54E+00 |
| Cr | 49  | 3.99E+07 | 2.54E+03 |
| Cr | 51  | 2.38E+08 | 2.39E+06 |
| Cr | 55  | 1.99E+08 | 2.10E+02 |
| Cr | 56  | 1.40E+08 | 3.56E+02 |
| Cr | 57  | 1.99E+07 | 2.11E+01 |
| Cr | 58  | 5.98E+07 | 7.00E+00 |
| Mn | 51  | 3.99E+07 | 2.77E+03 |
| Mn | 52  | 5.98E+07 | 4.83E+05 |
| Mn | 52m | 3.78E+02 | 1.27E+03 |
| Mn | 54  | 1.85E+08 | 2.70E+07 |
| Mn | 56  | 4.19E+08 | 9.28E+03 |
|    |     |          |          |


- For the all component of the pre-separator, induced activity was calculated and dose rate around the pre-separator due to the decay gamma.
- The operation time of 5000 hour (in a year) was assumed, conservatively.
- U-238 beam with 400 MeV/u was applied as the primary beam.




Activities and dominant nuclides in each component



 Decay gamma spectra were estimated at each component and cooling time step for evaluating shutdown dose rate.



- Dose rate was evaluated by the decay gamma spectra from the irradiated pre-separator.
- The target and collimator are dominant components contributing to the exposure after a shutdown.



#### **Concrete activation**

- It is difficult to predict the composition of the concrete including impurities at the design stage.
- The density and composition of the ANSI/ANS 6.4-1977 was applied in the shielding calculation and activation analysis for the IFF target facility.
- Additionally, impurities was assumed based on the experiment data of other facilities.

#### **Concrete composition**

| 원소        | weight %   |  |  |
|-----------|------------|--|--|
| Н         | 7.6433E-03 |  |  |
| 0         | 4.9724E-01 |  |  |
| Si        | 3.1507E-01 |  |  |
| Ca        | 8.2378E-02 |  |  |
| Na        | 1.6985E-02 |  |  |
| <u>Mg</u> | 2.5478E-03 |  |  |
| Al        | 4.5435E-02 |  |  |
| S         | 1.2739E-03 |  |  |
| K         | 1.9108E-02 |  |  |
| Fe        | 1.2314E-02 |  |  |
| Со        | 1.00E-03   |  |  |
| <u>Eu</u> | 1.00E-04   |  |  |
| <u>Li</u> | 2.00E-03   |  |  |
| Ni        | 2.00E-03   |  |  |
| <u>Cs</u> | 1.00E-03   |  |  |

**Impurities** 

| ㅁ해조            | <u>모핵종</u> 핵반응 |                | 불순물 함량, [ppm] |        |        |        |       |
|----------------|----------------|----------------|---------------|--------|--------|--------|-------|
| <u></u>        | 백건궁            | 생성핵종           | Ref. 1        | Ref. 2 | Ref. 3 | Ref. 4 | 적용값   |
| <u>Li</u> -6   | n, α           | H-3            | 20.00         | _      | _      |        | 20.00 |
| Co-59          | n, y           | Co-60          | 10.00         | 3.92   | 10.00  | 2.20   | 10.00 |
| <u>Ni</u> -58  | n, p           | Co-58          | 30.00         |        | _      |        | 30.00 |
| <u>Ni</u> -62  | n, y           | <u>Ni</u> -63  |               |        | _      | 2.20   | _     |
| <u>Cs</u> -133 | n, y           | <u>Cs</u> -134 | _             | 1.20   | 1.20   | 0.03   | 1.2   |
| <u>Eu</u> -151 | n, y           | <u>Eu</u> -152 | 0.37          | 0.17   | 0.80   | 0.00   | 0.80  |
| <u>Eu</u> -153 | n, y           | <u>Eu</u> -154 | 0.40          |        |        | 0.0019 | 0.4   |

Ref.1: KOPEC internal material

Ref.2: T. Zager et. Al., "Long-lived activation products in TRIGA Mark II research reactor concrete shield: Calculation and experiment," Journal of Nuclear Materials, 335 (2004) 379-386


Ref.3: K. Masumoto et. Al., "Evaluation of reactivity induced in the accelerator building and its application to decontamination work," Journal of Radioanalytical and Nuclear Chemistry, Vol. 255, No. 3 (2003) 465-469

Ref.4: G. Hampel et. Al., "Calculation of the activity inventory for the TRIGA reactor at the medical university of Hannover(MHH) in preparation for

dismantling the facility," WM'02 Conference, Feb. 24-28, 2002, Tuson, AZ, U.S.

#### **Concrete activation**

- Operation condition: 30 years operation, 5000 hours per year is applied as the operation time.
- Most reaction of impurities, producing radio-active nuclides, is capture reaction,  $(n,\gamma)$ . Because the hard neutron spectra (high energy neutrons dominant) of the source term, the increase in the activity is about 1.5 times.



## Summary, experience and discussion

- The radiation shielding analysis for the IFF target facility of RAON was performed in this study.
- At first, the source terms and bulk shield thickness were evaluated. Secondly, the dose rate distribution during an operation was estimated and produce the dose map. Finally induced activities and shutdown dose distribution were evaluated.

- In the activation calculation, impurities may affect the calculation results. But it is difficult to predict the composition and contents of impurity during the design step.
- For the large-scale facility, obtaining enough low rel. error is not easy in the MC calculation. In this study, Advantg code producing www file was used. It was very useful in the reduction of the computation time.
- I also expect more powerful modelling tool will be developed.